

STATIONS DE POMPAGE

Nom (Situation)	Propriétaire	Alt. TP [m]	Caractéristique		
			Q [l/min]	HMT [m]	Tampon [m3]
SP Chamblon (Chamblon)	Chamblon	533	5x533	85	0.5 ?
SP Cuarny (Cuarny)	Cuarny	560	2x100	70	50
SP Method (Method)	Method	438	2x270	68	35-40
SP des Râpes (Vugelles-la- Mothe)	Orges	530	2x120	112	20
SP du Gy (Pomy)	Pomy	540	2x100	68	?
SP Valeyres (Valeyres)	Valeyres-sous-Montagny	499	2x215	45	rés.
SP Châtelard (YLB)	YLB	433	1x1500 1x3000 1x4500	100	-
SP Beauregard (YLB)	YLB	519	1x540 2x1080 1x1500	110 130 130	rés.
SP Pomou (YLB)	YLB	441	2x900	53	0.5
SP Pomest (Cuarny)	YLB	528	2x900	76	0.2
SP Montélaz (Cuarny)	YLB	622	1x300	64.3	0.2
Station Bellerive (Grandson)	YLB	432	3x8400	120	-